

IHS & COCOPAH INDIAN TRIBE

Requests for Information and Responses

June 20, 2025

Questions:

- 1. Will the district consider SprayWall Sprayroq as an alternative coating system for this project?**

Yes, the SprayWall as manufactured by Sprayroq is considered an approved coating system.

- 2. Will the district allow new Ameron PVC products, obtained prior to the business closure, for the existing PVC repairs?**

No, new Ameron PVC products obtained prior to the business closure are not allowed for existing PVC repairs.