

IHS & COCOPAH INDIAN TRIBE

Requests for Information and Responses

July 1, 2026

Questions:

- 1. On drawing C3, the scale is 1" = 5', but when checking known dimensions, such as the wet well pad or the wet well discharge pad, the scaled dimensions do not match. Please confirm what scale the drawing was drafted with, and can be utilized for making measurements on the respective plan sheet.**

The scale is 1"=5' as the full-size drawing. If the contractor is printing the drawing 11x17 or half size, the scale will be off. The best solution is using the scale bar with 1" = 10' for the 11x17 or half size.

- 2. Will a soils report be provided for this bid?**

Please see Addenda No.2 for the Geotechnical Report.

END OF RFI AND RESPONSES #2