

IHS & COCOPAH INDIAN TRIBE

Requests for Information and Responses

July 25, 2025

Questions:

- 1. Will the district consider SprayWall Sprayroq as an alternative coating system for this project?**

Yes, the SprayWall as manufactured by Sprayroq is considered an approved coating system.

- 2. Will the district allow new Ameron PVC products, obtained prior to the business closure, for the existing PVC repairs?**

No, new Ameron PVC products obtained prior to the business closure are not allowed for existing PVC repairs.

- 3. For bid item #6 – bolt replacement and cover rehab; can you please clarify if we are just replacing the bolts or we are removing and replacing the frame and cover with bolts.**

See Technical Provisions Section 08 – Manhole Rehabilitation, TP – 08.09 Manhole Frame and Cover Rehabilitation, C Bolt Replacement on Covers (page 214 of 395) and Technical Provisions Section 08 – Manhole Rehabilitation, TP – 08.16 Method of Measurement and Basis of Payment, D Bolt Replacement on Covers (page 222 of 395) of the RFP.

- 4. For item 5 of the legend on sheet 5 of the planset; Does this refer to line item 7 on the bid table?**

Yes, item 5 of the legend on the planset refers to bid item 7.